Overcoming Challenges Demand Response and Peak Load Reductions



Heather Langford U.S. Green Building Council





Ella Sung Lawrence Berkeley National Laboratory

Peter Sopher Environmental Defense Fund



Leadership in Energy and Environmental Design

A leading-edge system for certifying the greenest performing buildings in the world



total countries and territories with LEED® PROJECTS

PROJECTS ARE CURRENTLY PARTICIPATING IN LEED®, COMPRISING MORE THAN BILLION ET OF CONSTRUCTION SPACE

MILLON square feet certifies to LEED[®] EACH DAY









USGBC MEMBERS

are organizations, corporations and institutions that make up a vibrant and diverse community

LEED[®] credentials have been earned by building professionals across all areas of practice




GREENBUILD 2013

Approximately one third of the power grid load is attributable to the commercial building community. (Source: U.S. Energy Information Administration)

Can LEED Buildings do even better...when called upon to do so?


TIMES change... THERMOSTATS should, too!

These new **STRAIGHT-LINE** 'stats by White-Rodgers match the modern mode . . . let you pocket more profits





ADR for Peak Reduction



See back fold for specifications



PushButton ... The Ultimate in Home Comfort Control



Driving Market Transformation



LEED v2009

→ Pilot Credit 8 for 1 point

LEED v4

 \rightarrow EA Credit for up to 3 points

LEED Credit for Demand Response

- → Case 1: Demand Response Program Available
- → Case 2: Demand Response Program Not Yet Available
- → Case 3: Permanent Load Shedding (EB only)

LEED Credit Requirements

- \rightarrow Real-time, fully-automated demand response (ADR)
- → Minimum 1-year contractual commitment with intention of multi-year renewal
- → 2009 pilot credit: 10% or more of the estimated peak electricity demand **or** a minimum of 20 kW, whichever is greater
- → v4 credit: 10% or more of the estimated peak electricity demand

LEED O+M: Existing Buildings I v4 Demand response	
Possible 3 points	
Language Guide Resources Forum	
	Glossary

Intent

To increase participation in demand response technologies and programs that make energy generation and distribution systems more efficient, increase grid reliability, and reduce greenhouse gas emissions.

Requirements

Establishment

Evaluate building systems and equipment for participation in a demand response program. On-site electricity generation does not meet the intent of this credit.

LEED O+M: Existing Buildings v4 Demand response	
Possible 3 points	
On-line Referen	<u>ce Guide</u>
Language Guide Resources Forum	All credits 🐟 Previous Next

Free Preview!

This web-based reference guide credit is being provided as a free preview. For more information on the web-based guide check out usgbc.org/guide. To purchase access to the full suite of guide content, go to the store.

Behind the Intent	Glossary 🕥 🔍 🔍	Demand Response in Practice: How it Works
Step-by-Step Guidance	Behind the Intent	
Required documentation		Demand Response in Practice: How it Works
Further explanation +	When temperatures rise or fall dramatically, use of air-conditioning or heating increases. The electricity grid must respond quickly, especially in urban areas and	
Related credit tips	places where commercial buildings or industrial operations are clustered. Utilities work to keep the system operating in balance, reliably, and at reasonable cost.	
Changes from LEED 2009	Demand response (DR) strategies encourage electricity customers to reduce their usage during peak demand times, helping utilities optimize their supply-side energy generation and delivery systems. One strategy is tiered demand electricity pricing.	

Challenges to Adoption

- → Limited number of energy-focused facility managers
- → Lack of familiarity with utility DR programs
- → Lack of specific knowledge around costs and benefits
- → Perception that demand response is disruptive
- → Concern over loss of control
- → Concerns over ongoing operational changes

Demand Response Partnership Program

Market Transformation

- → Drive adoption of demand response in commercial buildings and facilitate their participation in grid reliability and smart grid initiatives.
- \rightarrow Inform the new LEED demand response credit.
- → Develop a stronger relationship between the energy and building communities.

Program Goals

- → Generate and maintain interest in ADR
- → Reveal customer responsiveness and perceived barriers to adopting ADR
- → Quantify economic, environmental & grid benefits delivered by ADR
- → Serve as a foundation to bring together utilities, service providers and customers to continue the transformative journey of ADR at the company, state and national levels

Who We Are













Outreach

Targeted LEED registered and certified buildings

- \rightarrow Emails, phone calls, in-person meetings
- → Webcasts, press releases
- → USGBC chapter resources
- Outcomes
 - → 572 buildings representing 275 million sq ft selected for initial outreach
 - → 133 buildings (51 million sq ft) enrolled, evaluating enrollment, or are DR ready

- → Consumer energy use behavior and barriers to participation
- → Customer financial analysis and cost-effectiveness
- → System-wide impacts, including environmental and reliability impacts
- → Performance assessment and estimation in commercial buildings
- \rightarrow Establishing baselines and peak load benchmarking
- → Education, best practices, and business cases for both the energy and building communities




Heather Langford Director, LEED U.S. Green Building Council hlangford@usgbc.org

Quantifying Benefits of DR Performance in Commercial Buildings

Ella Hae Y. Sung

Senior Researcher Lawrence Berkeley National Lab

How do we measure DR Performance?



Increasing Speed of Telemetry


A DR event has three phases of curtailment

•Phase 1: Ramp Period

•Phase 2: The Sustained


Response Period

•Phase 3: Recovery Period




Key Building Characteristics

- Building systems
- Building size
- Building type (e.g., office, retail, cold storage, etc.)
- Occupancy schedule
- Load characterization peak load time and magnitude
- Load variability
- Weather sensitivity



Weather Sensitivity



What metrics are most useful to prioritize DR enablement of buildings?

- Response time
- Reliable load reductions
- Reduce load while maintaining comfort

Each of these is influenced by properties of building systems and occupancy.

Demand Response Database

- Distinctions made according to
 - Building location
 - DR program
 - Building type
 - Building Size
 - DR strategies
- Analysis tool to identify load variability between days, weather sensitivity of loads, load ranges and load shed in response to DR events over time
- Choice of baseline development options

What is Baseline?

10/10 Baseline

- Averages from similar 10 days
- assumes that historic information is a good predictor of today's use
- Adjustment Ratio* used in 10/10 Baseline

Average kWh usage of the first 3 of the 4 hours before the DR event

Adjustment Ratio =

Average kWh usage for the same 3 hours from the past 10 similar days (excluding event days, weekends, and holidays)

Why Baseline Matters

- Compare similar days
- Baseline compensates for energy usage differences outside of DR events.

Гуре	: XY Baseline 🔹			
< = [Ac	Baseline: Y = Ijust Baseline ate Baseline			
		Adjustment		
	Parolinar		Adjustme	ent
	Baselines	Start Time		ent Cap Percentage
	Baselines	Start Time 08:00:00		

DR Metrics for Load Characterization


- Load shed (kW): historically most reported figure of merit but lacks context
- Peak load magnitude and timing: good to compare the timing of DR event across days

Relevant Metrics

- Load shed per Floor Area (W/ sq. ft)
- Whole Facility Power % (WFP%)
- DR Enablement Costs (\$/kW)*


Site #224, Whole Facility Power (kW), 2013-08-28

Max OAT 87.8905459861271 F



Site #220, Whole Facility Power (kW), 2013-08-30

Max OAT 97.8881251481362 F




Thank you.

Peter Sopher, Policy Analyst, Clean Energy Environmental Defense Fund

Key Takeaways:

- → Our contribution: An original approach to analyzing emissions impact of demand response using empirical data.
- → Our results: For each of our three scenarios, emissions during peak hours are lower during demand response event days than on corresponding baseline days.



Essential Data

- → Hourly grid electricity generation mix, disaggregated by fuel source.
- → Emissions factors for fossil fuel sources.
- → Building-specific demand for DR event days and baselines.

Table 2 – Essential Data		
Variable	Units of Measure	
Grid-Level Hourly Electricity Generation	MWh	
Disaggregated by Fuel Source, Summer '13		
Total	MWh	
Thermal	MWh	
Imports	MWh	
Nuclear	MWh	
Hydro (large-scale)	MWh	
Renewables (aggregated)	MWh	
Geothermal	MWh	
Biomass	MWh	
Biogas	MWh	
Hydro (small-scale)	MWh	
Wind	MWh	
Solar PV	MWh	
Solar Thermal	MWh	
Emissions Factors for Fossil Fuel Sources	(MtCO2e)/(kWh)	
Thermal	(MtCO2e)/(kWh)	
Imports	(MtCO2e)/(kWh)	
Building-Specific Demand for DR Event Days and Baselines, Summer '13	кw	
Generation Mix Emissions Efficiency (GMEE)	(kWh)/(MtCO2e)	
Generation Mix Emissions Intensity (GMEI)	(Emissions)/(kWh)	

SCE Buildings Data

Table 1 – DR Event Location and Timing						
DR Day	Site 220	Site 224	Site 227	Site 232	# of Events	Average Event Hours
June 28, 2013	Х	4-6pm	4-6pm	4-6pm	3	4-6pm
July 1, 2013	2-6pm	Х	Х	Х	1	2-6pm
July 3, 2013	2-6pm	Х	Х	Х	1	2-6pm
August 21, 2013	2-6pm	Х	Х	Х	1	2-6pm
August 28, 2013	2-6pm	2-6pm	Х	Х	2	2-6pm
August 30, 2013	2-6pm	Х	Х	Х	1	2-6pm
Sept. 4, 2013	2-6pm	Х	Х	Х	1	2-6pm
Sept. 6, 2013	2-6pm	Х	Х	Х	1	2-6pm
Sept. 9, 2013	Х	4-6pm	4-6pm	4-6pm	3	4-6pm
Sept. 13, 2013	2-6pm	Х	Х	Х	1	2-6pm
Sept. 23, 2013	2-6pm	Х	Х	Х	1	2-6pm
Sept. 30, 2013	2-6pm	Х	Х	Х	1	2-6pm
October 4, 2013	2-6pm	Х	Х	Х	1	2-6pm
October 17, 2013	2-6pm	Х	Х	Х	1	2-6pm
Total # of Events	12	3	2	2	19	Х
Average Event Hours	2-6pm	3:20-6pm	4-6pm	4-6pm	Х	2:38-6pm

Methodology Summary


- 1. Generation Mix Assessment: Using CAISO's data, calculate average hourly generation, disaggregated by fuel source, for all DR days and corresponding baseline days.
- 2. Load Impact Analysis: Using building-level data, for each DR event, we subtract the baseline day load from the DR event day load to determine the hours for which DR event day load is higher or lower than baseline load.

- 3. Emissions Impact Analysis: Based on these hourly DR event days versus baseline days' demand differences, we use three methods to calculate the emissions impact of DR days:
 - a. We multiply hourly demand difference on DR event days relative to baseline days by the sum of each fuel's product when the emissions factor for a fuel is multiplied by that fuel's percentage of CAISO's generation mix using:
 - a. The hourly generation mix for an average DR event day.
 - b. The hourly generation mix for an average baseline day.
 - c. DR event days use the DR day generation mix, while baseline days use the baseline day generation mix.


Load Impact Summary


	Table 3: DR Event Load Statistics by Building, Month, and DR Event				
		Demand Reduced on DR Days Relative to Baseline Days (KW)	Ave. Daily Baseline Load (KW)	% Demand Reduction on DR Days Relative to Baseline	DR Demand Lower than Baseline During Ave. DR Event Time
AVER	AGE (All Events)	160	19,153	0.8	Yes
b0	220	195	7,212	2.7	Yes
Building	224	(-775)	22,464	(-3.4)	Yes
uile	227	1,288	53,468	2.4	Yes
æ	232	225	51,519	0.4	Yes
	June	2,724	42,641	6.4	Yes
ي.	July	(-1,718)	5,513	(-31.2)	No
Month	August	(-295)	11,165	(-2.6)	Yes
Σ	Sept.	(-205)	20,257	(-1.0)	Yes
	October	564	9,125	6.2	Yes
	28-Jun	2,724	42,641	6.4	Yes
	1-Jul	(-2,080)	5,390	(-38.6)	No
	3-Jul	(-1,356)	5,636	(-24.1)	No
	21-Aug	(-472)	6,845	(-6.9)	Yes
s	28-Aug	(-774)	15,151	(-5.1)	Yes
Лау	30-Aug	837	7,512	11.1	Yes
Event Days	4-Sep	414	7,593	5.5	Yes
evel	6-Sep	1,631	7,336	22.2	Yes
DR I	9-Sep	(-2,048)	42,164	(-4.9)	Yes
-	13-Sep	1,592	7,238	22.0	Yes
	23-Sep	820	6,912	11.9	Yes
	30-Sep	47	6,486	0.7	Yes
	4-Oct	1,259	6,114	20.6	Yes
	17-Oct	(-132)	12,135	(-1.1)	Yes

Supplementary Load Impact Graphics



Supplementary Load Impact Graphics






Emissions Impact:


- → 3 methodologies used
 - 1. DR day generation mix used to assess emissions impact from both DR days and baseline days.
 - 2. Baseline day generation mix used to assess emissions impact from both DR days and baseline days.
 - 3. DR day generation mix used for DR days and baseline day generation mix used for baseline days.


Results:

- → For all three methodologies, emissions are lower on DR days than on baseline days during peak hours.
- → DR day emissions are lower on than baseline day emissions using methodologies (1) and (2), but higher using (3). Why?




Emissions Reductions on DR Days Relative to Baseline - Comparing Methodologies






Emissions Reductions on DR Days Relative to Baseline - Comparing Methodologies




Results Explained:

→ In our small sample, emissions intensive fuels comprised 75% of CAISO's daily generation mix on DR days versus 71% on baseline days.



... Continued:

- → Renewables comprised 12% of the generation mix on DR days and 14% on baseline days.
 - → This RE dip on DR days is particularly pronounced for wind power, which drops from 6.1% of the generation mix on baseline days to 4.5% on DR event days.



Applied Grid Level Emissions Impact:

→ Assuming 100% of CAISO buildings participate in DR in a similar fashion to the SCE buildings analyzed in this study, grid demand on DR days would be 5.4% lower, equating to 40,925 MW of demand reduced and 14,227 MtCO2e of emissions reduced.

Table 4 - Grid vs. Building Level DR Day Load Reductions			
	CAISO	SCE Buildings in This Study	
DR Day Demand	753,138 MW	18,993 KW	
Baseline Day Demand	718,269 MW	19,153 KW	
DR Day - Baseline	34,869 MW	-160 KW	
% Change	4.63%	-0.84%	

Table 5 - Applied Grid-Level Demand Reductions Assuming 100% DR Participation		
DR Day Demand	753,138 MW	
Applied Grid Level Demand for DR Days, Assuming 100% of Buildings Participate	712,214 MW	
% Reduction	5.4%	
Demand reduced	40,925 MW	
Emissions Reduced (Using DR Day CAISO Generation Mix)	14,227 MtCO2e	

THANK YOU

Peter Sopher <u>Psopher@edf.org</u>